

*Compliance Designs*

CLIENT: RTD Beverages, LLC  
72070 Hwy 1077  
Covington, LA 70433

DATE OF REPORT: Quarter 2, 2015  
REPORT #: 555-4163  
LABORATORY ID#: 514709

NOTE: "M" indicates that maximum levels have been exceeded, or in the case of pH, is either too high or too low  
"ND" indicates that none of this analyte has been detected at or above the specified detection level  
"MCL" indicates maximum contaminant level as established by US FDA for bottled water  
"RL" indicates laboratory reporting limit for method  
Units results are reported in mg/L unless other wise noted

ANALYSIS PERFORMED	MCL <sup>1</sup> (mg/L)	RL (mg/L)	GOODBEE WELL SOURCE 555-4163 (mg/L)
<b>Primary Inorganics</b>			
Antimony	0.006	0.001	ND
Arsenic	0.01	0.002	ND
Asbestos	7 MFL	0.2	ND
Barium	2	0.002	0.0067
Beryllium	0.004	0.001	ND
Cadmium	0.005	0.0005	ND
Chromium	0.1	0.005	ND
Cyanide	0.2	0.005	ND
Fluoride	See endnote <sup>2</sup>	0.05	0.16
Lead	0.005	0.0005	ND
Mercury	0.002	0.0002	ND
Nickel	0.1	0.005	ND
Nitrogen, Nitrate	10	0.1	ND
Nitrogen, Nitrite	1.0	0.05	ND
Nitrogen - NO3/NO2 (NOX)	10	0.1	ND
Selenium	0.05	0.005	ND
Thallium	0.002	0.001	ND
<b>Secondary Inorganics</b>			
Alkalinity	--	2	130
Aluminum	0.2	0.02	ND
Bicarbonate	--	2	150
Boron	--	0.05	ND
Bromide	--	0.005	0.016
Calcium	--	1	1.2
Carbonate	--	2	7.7
Chloride	250 <sup>3</sup>	0.5	2.2
Copper	1	0.002	ND
Corrosivity	--	-14	-0.29
Foaming Agents	--	0.05	ND
Hardness, Calcium	--	5	ND
Hardness, Total	--	3	3.0
Hydroxide	--	2	ND
Iron	0.3 <sup>3</sup>	0.02	ND
Magnesium	--	0.1	ND
Manganese	0.05 <sup>3</sup>	0.002	0.013
Orthophosphate	--	0.01	0.20
pH	See endnote <sup>4</sup>	0.1	8.9
Phenol	0.001	0.001	ND
Potassium	--	1	ND
Silver	0.1	0.0005	ND
Sodium	--	1	68
Specific Conductance	-- umho/cm	2	280
Sulfate	250	0.5	13
TDS	500 <sup>3,5</sup>	10	200
Zinc	5 <sup>3</sup>	0.02	ND

750 Royal Oaks Drive, Suite 100  
Monrovia, California 91016-3629  
Tel: (626) 386-1100  
Fax: (626) 386-1101  
1 800 566 LABS (1 800 566 5227)

**Client:** RTD Products, Inc.  
72070 Hwy 1077  
Covington, LA 70433  
**Attention:** Water Quality Manager - Covington, LA

**Report Date:** 05/13/2015

Parameter	Method	Reporting Limit	Result
<b>Sample ID: 555-4163 Goodbee Well Source</b>			<b>Sample #: 201501060804</b>
Magnesium, Total, ICAP	EPA 200.7	0.1	ND
Manganese, Total, ICAP/MS	EPA 200.8	0.002	0.013
Orthophosphate-P	4500P-E/365.1	0.01	0.20
pH (units)	SM4500-HB	0.1	8.9
Phenolic Compounds-low level	EPA 420.4	0.001	ND
Potassium, Total, ICAP	EPA 200.7	1	ND
Silver, Total, ICAP/MS	EPA 200.8	0.0005	ND
Sodium, Total, ICAP	EPA 200.7	1	68
Specific Conductance, umho/cm	SM2510B	2	280
Sulfate	EPA 300.0	0.5	13
Total Dissolved Solids (TDS)	E160.1/SM2540C	10	200
Uranium, Total, ICAP/MS	EPA 200.8	0.001	ND
Uranium, Total, ICAP/MS as pCi/L	EPA 200.8	0.7	ND
Zinc, Total, ICAP/MS	EPA 200.8	0.02	ND
<b>Physical</b>			
Color (ACU)	SM 2120B	3	ND
Odor at 60C (TON)	SM 2150B	1	ND
Turbidity (NTU)	EPA 180.1	0.05	0.070
<b>Volatile Organic Compounds</b>			
Benzene	EPA 524.2	0.0005	ND
Bromobenzene	EPA 524.2	0.0005	ND
Bromochloromethane	EPA 524.2	0.0005	ND
Bromodichloromethane	EPA 524.2	0.0005	ND
Bromoform	EPA 524.2	0.0005	ND
Bromomethane	EPA 524.2	0.0005	ND
n-Butylbenzene	EPA 524.2	0.0005	ND
sec-Butylbenzene	EPA 524.2	0.0005	ND
tert-Butylbenzene	EPA 524.2	0.0005	ND
Carbon Tetrachloride	EPA 524.2	0.0005	ND
Chlorobenzene	EPA 524.2	0.0005	ND
Chloroethane	EPA 524.2	0.0005	ND
Chloroform (Trichloromethane)	EPA 524.2	0.0005	ND
Chloromethane(Methyl Chloride)	EPA 524.2	0.0005	ND

All results reported in milligrams per liter unless otherwise noted.  
ND - Not detected at the specified limit